

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	6.7		1.0		Y
6	6.61		1.0		N
7	6.59		1.0		N
8	6.59		1.0		N
9					N
10					N
11	6.62		1.0		N
12	6.7		1.0		Y
13	6.59		1.0		N
14	6.7		1.0		Y
15					
16					
17					
18	6.59		1.0		N
19	6.59		1.0		N
20	6.60		1.0		N
21	6.63		1.0		N
22	6.58		1.0		N
23					N
24					N
25	6.7		1.0		Y
26	6.7		1.0		Y
27	6.64		1.0		N
28	6.75		1.0		Y
29	6.79		1.0		Y
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 9 1 6 7 1

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: September 2023  
Month/Year

Number of excursions\* during this month: 15  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by STATE:**

pH	<span style="border: 1px solid black; padding: 2px;">6.7</span>	
Alk	<span style="border: 1px solid black; padding: 2px;"></span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 2px;">1.</span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 2px;"></span>	(_____)

9/27/23 Soda Ash treatment system now on-line for pH correction.

Print Name: Michael Ruark  
 Signature: Mike Ruark  
 Date: 9/29/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 15