

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1						Illimitation
2	7.12		1.0		Y	been met for this day? PWS ID: 41 9 1 6 7 1
3						System Name: DIXIE ELEMENTARY SD 509J
4	7.15		1.0		Y	
5	7.13		1.0		Ý	Entry Point: EP-A
6			1			Sample Period: January 2024
7				ď		Month/Year
8	7.05		1.0		Y	Number of excursions* during this month:
9						(Count the number of days when any WQP was
10	7.26		1.0		Y	less than the minimum required)
11			e			
	7.20		1.0		Y	Total excursions during the previous 5 months:
13						(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
14					-	roint and Distribution excursions are cumulative )
15		·				For OHA use only
16						
17 18	1000	-	-			Minimum Water Quality
	7.011		1.0		4	Parameters as set by STATE:
20	7.24		1.0	-	7	pH 6.7
21						Alk (Alkalinity)
	7.2		≈1.4		7	PO4 1. (Orthophosphate)
23	7.06		~[[		1	Other ()
	7.18		≈1.25		7	
25	1		1,000			
26	7.19		≈1.25°		Y	
27			,,,,,		-	Print Name: Mike Roack
28						
29						Signature: Millian Showl
30						Date: 2/02/2024
31						Send to DWP within 10 days after end of sampling period
o = N	I = Exc	ursion	) Tota	l N's	0	Sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/