

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have< th=""></have<>
1	7.15		1.0		Y	minimums ENTRY POINT
2	7.12		1.0		Y	been met for this day? PWS ID: 41 9 1 6 7 1
3						
4		-:				System Name: DIXIE ELEMENTARY SD 509J
5	7.24	_	1.0		Y	Entry Point: EP-A
6						Sample Period: February 2024
7	7.18		1.0		Y	Month/Ýear
8						Number of excursions* during this month:
9	7.26	· · · · · ·	1.0		Y	(Count the number of days when any WQP was
10						less than the minimum required)
11	3.25	<u></u>	20		Y	-wrong Date
12	7.26		1.0		Y	Total excursions during the previous 5 months:
	736	mon	g Dat	2	•	(Over 9 excursions in 6 months is a violation. Entry
14	7.36		1.0		4	Point and Distribution excursions are cumulative)
15	2					For OHA use only
16	7.21					. o. o. u. ado o.ny
17				-		Minimum Water Quality
18						Parameters as set by STATE:
	7.19		1.0		Y	
20						pH 6.7
21	7.19	·	1.0		Y	Alk (Alkalinity)
22	7.24		1.0			PO4 1. (Orthophosphate)
23						Other
24						
25						
26	7.15		1.0		Y	
27						Print Name:
28	7./3		1.0		Y	Signature:
29					7	Signature:
30					,	
31						Send to DWP within 10 days after end of

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/