

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	<>Have ENTRY POINT
1						minimums ENIRT POINT been met for
2						this day? PWS ID: 41 9 1 6 7 1
3						System Name: DIXIE ELEMENTARY SD 509J
	6.99		1.0		Y	Entry Point: EP-A
5	/ OF	-	1 0		Y	Sample Period: March 24
6 7	6.85		1,0	\vdash	7	Month/Year
8	·					Number of excursions* during this month:
9					,	(Count the number of days when any WQP was
10	,					less than the minimum required)
	7,27		1.25		Y	
12	1		1.25)	ME	-	Total excursions during the previous 5 months:
13	7.35	4	1 de		У	(Over 9 excursions in 6 months is a violation. Entry
14			- '		7	Point and Distribution excursions are cumulative)
15	7.19		1.0		Y	For OHA use only
16					,	7 G. G. W. C. G. G. M.
17						Minimum Water Quality
	7.41		1.0		Y	Parameters as set by STATE:
19						pH 6.7
	7.47		1.0		Д	Alk (Alkalinity)
21	77		1 0			PO4 1. (Orthophosphate)
22	7.17		1.0		$\not\vdash$	Other (
23 24						
25	7.09		1.0		$\frac{1}{\sqrt{1}}$	
26	7,0 (1.0	-	7	
27	7.19		1.0	 		Britishama Mika Q
28	,,,,	, , , , , , , , , , , , , , , , , , , ,			/	Print Name: Mike Roar K Signature: Mike Roar K
29	7.36		1.0		y	Date: 4/01/2024
30	- 400				1	
31						Send to DWP within 10 days after end of sampling period
0 = 1	V = Exc	ursion) Tota	al N's	0	Sampling period