

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.37		1.0		Y
2					
3	7.24		1.0		Y
4	7.23		1.0		Y
5	7.27		1.0		Y
6					
7					
8	7.36		1.0		Y
9					
10	7.25		1.0		Y
11					
12	7.31		≈1.25		Y
13					
14					
15	7.19		≈1.15		Y
16					
17	7.16		≈1.2		Y
18					
19	7.18		≈1.2		Y
20					
21					
22					
23	7.20		1.0		Y
24					
25	7.19		1.0		Y
26	7.21		1.0		Y
27					
28					
29	7.28		1.0		Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: April 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by STATE:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Mike Ruark

Signature: Michael Ruark

Date: 5/01/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's