

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.36		1.0		Y
3					
4					
5	7.28		1.0		Y
6					
7	7.09		1.25		Y
8					
9	7.08		1.25		Y
10					
11					
12	7.11		1.25		Y
13					
14					
15	7.12		1.0		Y
16					
17					
18					
19					
20					
21					
22	7.2		1.0		Y
23	7.08		1.0		Y
24					
25					
26	7.12		1.0		Y
27					
28	7.19		1.0		Y
29					
30	7.17		1.0		Y
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: August 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by STATE:**

pH	<input type="text" value="6.7"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1."/>	(Orthophosphate)
Other	<input type="text"/>	( )

Print Name: Mike Buark

Signature: [Signature]

Date: 9/6/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's