

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1	7.44		1.0		Y	minimums
2	7.38		1.0		Ý	been met for this day? PWS ID: 41 9 1 6 7 1
3						System Name: DIXIE ELEMENTARY SD 509J
4	7.29		1.0		Y	
5				ļ		Entry Point: EP-A
6						Sample Period: October 2024 Month/Year
7	7.26		1.0		У	
8					/	Number of excursions* during this month:
9	7.33	·	1.0	:	Y	(Count the number of days when any WQP was
10						less than the minimum required)
11	7.36		1.0		Y	Total accounting during the province 5 province
12						Total excursions during the previous 5 months:
13						(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
14 15	7.37		1.0			Tome and Biothbatton executions are camerative,
16	7.18		1.0	-		For OHA use only
17	7.10	L	1.0		1	
18	7.16		1.0		У	Minimum Water Quality
19	7.10		1.0		7-	Parameters as set by STATE:
20					$\vdash \vdash \vdash$	pH 6.7
21	7.13	<u> </u>	1.0		У	Alk (Alkalinity)
22	1.1.5	_	··· •	·		PO4 1. (Orthophosphate)
23	7.10		1.0		N/	Other
24	,	24			1	
25	7.09		1.5		V	
26				-	1	
27						Print Name: Mike Roark
28	7.19		1. 5		V	Signature: Much
29						Date: 11/04/2024
30	7.14		1.0		Y	Send to DWP within 10 days after end of
31]			sampling period
lo = N = Excursion) Total N's						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/