

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.09		1.0		Y
3					
4	7.16		1.0		Y
5					
6	8.35		1.0		Y
7					
8					
9	6.88		1.0		Y
10					
11	6.96		1.0		Y
12					
13	7.00		1.0		Y
14					
15					
16	7.28		1.0		Y
17					
18	7.30		1.0		Y
19					
20	7.28		1.0		Y
21					
22					
23	7.41		1.0		Y
24					
25					
26					
27	7.43		1.0		Y
28					
29					
30	7.43		1.0		Y
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: December 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by STATE:**

pH	<input type="text" value="6.7"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1."/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Michael Buark

Signature: *Michael Buark*

Date: 1/03/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

4