

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.38		1.0		Y
3					
4					
5					
6	7.23		1.0		Y
7					
8	7.19		1.0		Y
9					
10	7.18		1.0		Y
11					
12					
13	7.16		1.0		Y
14					
15					
16					
17	7.08		1.0		Y
18					
19					
20					
21	7.12		1.0		Y
22					
23	7.10		1.0		Y
24	7.15		1.0		Y
25					
26					
27	7.20		1.0		Y
28					
29	7.31		1.0		Y
30					
31	7.44				

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 9 1 6 7 1

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: January 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by STATE:

pH 6.7
Alk (Alkalinity)
PO4 1. (Orthophosphate)
Other ()

Print Name: Mike Buark

Signature: [Signature]

Date: 02/04/2025

Send to DWP within 10 days after end of
sampling period