

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.15		1.0		Y
4					
5	7.33		1.0		Y
6					
7	7.17		1.0		Y
8					
9					
10	7.08		1.0		Y
11					
12	6.98		1.0		Y
13					
14	7.27		1.0		Y
15					
16					
17					
18	7.60		1.0		Y
19	7.64		1.0		Y
20					
21	7.47		1.0		Y
22					
23					
24	7.47		1.0		Y
25					
26	7.38		1.0		Y
27					
28	7.36		1.0		Y
29					
30					
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: FEBRUARY 2025
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by STATE:**

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Mike Buark

Signature: [Signature]

Date: 3/04/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's