

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< Have ENTRY POINT	
1						IIIIIIIIIIIII	
2	7.30		1.0		Y	been met for this day? PWS ID: 41 9 1 6 7 1	
3						uns day:	
4	7.12		1.0		4	System Name: DIXIE ELEMENTARY SD 509J	
5						Entry Point: EP-A	
6						Sample Period: APRIL 2025	
7	7.12		1.0		y	Month/Year	
8						Number of excursions* during this month:	
$\overline{}$	7.07		1.0		У	(Count the number of days when any WQP was	
10	,				(less than the minimum required)	
11							
12		,				Total excursions during the previous 5 months:	
13						(Over 9 excursions in 6 months is a violation. Entry	
14	7.14		1.0		Y	Point and Distribution excursions are cumulative)	
15						For OHA use only	
16	7.19		1.0		Y		
17						Minimum Water Quality	
18	7.17		1.0		7	Parameters as set by STATE:	
19						pH 6.7	
20	,			·		Alk (Alkalinity)	
21						PO4 1. (Orthophosphate)	
22	7.31		1.0		Y	Other (Constitution)	
23	7.26		1.0		¥		
24		-					
25	7.30		60		y		
26	-7	-				Wrong Date Print Name: Mike Bus K	
27	7.27	}	1.1)	7	Print Name: Mike Buark	
28	7.27		1. 1	_	7	Signature:	
29	720		1. ^			Date: 5/05/25	
30	7.38		1.0		X	Send to DWP within 10 days after end of	
31			\ T -4	 		sampling period	
10 = L	o = N = Excursion) Total N's						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/