

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk F	Phos	Other	Y/N	ENTRY POINT
1						minimums ENIRT POINT been met for
2				T		this day? PWS ID: 41 9 1 6 7 1
3	F.26	, . , .	1.0		Y	System Name: DIXIE ELEMENTARY SD 509J
4	7.29		1.0		Ÿ	
5						Entry Point: EP-A
6	:					Sample Period: June 2025
7			:			Month/Year
8						Number of excursions* during this month:
9	7.69		1.0		y	(Count the number of days when any WQP was
10	_					less than the minimum required)
11	7.44		1.0		Y	
12						Total excursions during the previous 5 months
13	7,42		1.0		X	(Over 9 excursions in 6 months is a violation. Entry
14						Point and Distribution excursions are cumulative)
15						For OHA use only
16	7.45		1.0		7	
17						Minimum Water Quality
	7.43		1.0		У	Parameters as set by STATE:
19						pH 6.7
20	7.40	1.1	1.0		X	Alk (Alkalinity)
21						PO4 1. (Orthophosphate)
22	7					Other (Cranophiato)
23	7.41	<u> </u>	.0		7	0.1101
24	7.440					
25 26	7.43	1	1.0		}	
26 27	7 00				$\stackrel{\prime}{-}$	
28	7.37	***	1.0		7	Print Name: Mike Buark
20 29				-	_	Signature:
_	720		15		-	Date: 6/30/25
30 31	7.35		.15			Send to DWP within 10 days after end of
91	1.1					sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/