

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.35		1.0		y
3					
4					
5					
6					
7					
8	7.33		1.0		y
9	7.34		1.0		y
10					
11	7.38		1.0		y
12					
13					
14	7.41		1.0		y
15					
16	7.42		1.0		y
17					
18	7.40		1.0		y
19					
20					
21	7.45		1.1		y
22					
23	7.40		1.0		y
24					
25	7.39		1.0		y
26					
27					
28	7.38		1.0		y
29					
30	7.33		1.0		y
31					

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: July 2025  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameters as set by STATE:**

pH   
Alk  (Alkalinity)  
PO4  (Orthophosphate)  
Other  ( )

Print Name: Mike Beard

Signature: [Signature]

Date: 7/30/25

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0