

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	
1	7.33		1.0	: ::-	Y	riminionis
2		-				been met for this day? PWS ID: 41 9 1 6 7 1
3		v				System Name: DIXIE ELEMENTARY SD 509J
4	7.46		100		Y	
5						Entry Point: EP-A
6	7.45		1.0		Y	Sample Period: August 2025 Month/Year
7	,					
8	7.31		1.0		Y	Number of excursions* during this month:
9						(Count the number of days when any WQP was
10	, a.					less than the minimum required)
11						
12	7.32		1.0		\	Total excursions during the previous 5 months: (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative) For OHA use only
13					. 4	
14	7.41		1.0		Y	
15	7.37		1.0		\mathcal{A}	
16 17	-					
18	7.0		1.0			Minimum Water Quality
19	7.28		1.0	. :	Y	Parameters as set by STATE:
20	720		1,0		\	pH 6.7
21	7,34		110		7	Alk (Alkalinity)
22	7,33		1.0		VI:	PO4 1. (Orthophosphate)
23	7,25		1.0		7	Other ()
24	7.25	-	1.0		$\overline{\ \ }$	
25	1,22		1.0	·	_/-	
26	7.23		1.0		7	
27				:	-	Duint Names Adda 52
28		•				Print Name: Mike Boask Signature:
29	7.22		1.0		7	Date: 9/3/2025
30	.,				7	1
31	— ·					Send to DWP within 10 days after end of
o = N	l = Exc	ursion) Tota	l N's	\overline{C}	sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/