

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.28		1.0		Y
3					
4	7.29		1.0		Y
5	7.33		1.0		Y
6					
7					
8	7.30		1.0		Y
9	7.24		1.0		Y
10	7.32 <small>wrong date</small>				
11	7.32		1.0		Y
12	7.22		1.0		Y
13					
14					
15	7.23		1.0		Y
16					
17	7.13		1.1		Y
18	7.15		1.0		Y
19	7.19		1.0		Y
20					
21					
22	7.16		1.1		Y
23	7.26		1.1		Y
24					
25					
26					
27					
28					
29	7.09		1.4		Y
30	7.07		1.4		Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: December 2025
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by STATE:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Mike Boask

Signature:

Date: 1/5/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

17.5°C