

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.15		1.1		Y
3					
4					
5	7.28		1.15		Y
6					
7	7.47		1.0		Y
8					
9	7.51		1.0		Y
10					
11					
12	7.36		1.0		Y
13	7.25		1.0		Y
14	7.25				
15					
16	7.20		1.0		Y
17					
18					
19					
20	7.95		1.0		Y
21	7.45				
22	7.26		1.0		Y
23	7.24		1.0		Y
24					
25					
26					
27	7.17		1.0		Y
28	7.15		1.0		Y
29					
30	7.40		1.0		Y
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: January 2026  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by STATE:**

pH	<input type="text" value="6.7"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1."/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Mike Puask

Signature: 

Date: February 2<sup>ND</sup> 2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's