

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.37		1.0		Y
3					
4	7.40		1.0		Y
5					
6	7.38		1.0		Y
7					
8					
9	7.28		1.0		Y
10					
11	7.23		1.0		Y
12					
13	7.27		1.0		Y
14					
15					
16	7.23		1.0		Y
17					
18					
19	7.24				
20	7.20		1.0		Y
21					
22					
23	7.18		1.0		Y
24					
25	7.09		1.0		
26					
27					
28					
29					
30	7.09		1.0		Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: MARCH 2026
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by STATE:

pH	<input type="text" value="6.7"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1."/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Mike Buark

Signature: 

Date: 3/31/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's