

Day	pH	Alk	Phos	Other	Y/N
1	7.28		1.0		Y
2					
3	7.17		1.0		Y
4					
5		Corrected			
6	6.49	6.75	1.0		Y
7	7.49		1.0		Y
8	7.25		1.0		Y
9					
10	7.33		1.0		Y
11					
12					
13					
14	7.35		1.25		Y
15					
16	7.44		1.25		Y
17	7.60		1.0		Y
18					
19					
20	7.30		1.0		Y
21					
22	7.23		1.0		Y
23	<del>7.23</del>		<del>1.0</del>		<del>Y</del>
24	7.28		1.0		Y
25					
26					
27					
28	7.24		1.0		Y
29					
30	7.35		1.0		Y
31	7.26		1.0		Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: MAY 2024  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by STATE:**

pH	<input type="text" value="6.7"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1."/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Wrong Day

Print Name: Mike Buark  
Signature: [Signature]  
Date: 6/3/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's