

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| of human services | | | | | | | | |
|-------------------|---|----------------|-----------------|--------------|--------------|---------------------------------------|--|--|
| Day | рН | Alk | Phos | Sili | Y/N | <td>County; Linn Agency; Linn</td> | County; Linn Agency; Linn | |
| 3/1 | 7.5 | | | | | minimums | er ENTRY POINT | |
| 3/7 | 2.4 | | | | | been met f this day? | EP-A | |
| 3/8 | 7.5 | | | | | Lino day: | | |
| 3/9 | 7.3 | | | | | | PWS ID 4191707 | |
| 3/10 | 7.4 | | | | | | PLEASANT VALLEY ELEM SD #55 | |
| 3/14 | 7.3 | | | | | | | |
| 3/5 | 73 | | | | | Sample period: March 2022 Month/Year | | |
| 3/16 | 7.4 | | | | | | | |
| 3/18 | 7.3 | | | | | Ĺ | | |
| 3/2) | 7.4 | | | | | | \sim | |
| 3/27 | 7.4 | | | | | Numbe | r of excursions during this month: | |
| 3/23 | 7.3 | | | | | (Over 9 | excursions in 6 months is a violation. Entry | |
| 3/24 | 2.4 | | | | | | nd Distribution excursions are cumulative). | |
| 3/28 | <u> 7.3 </u> | | | | | | ursion' is any day in which the water quality | |
| 329 | 7.4 | | | | | 1 · | ter(s) fall below the minimum set by the | |
| 3/30 | <u> 7.5</u> | | | | | State. | | |
| 3/31 | 7.4 | | | | | | Reference emailed 4/6/2022 | |
| | | | | | | | | |
| | | | | | | | Minimum Water Quality | |
| | | | | | | | Parameter(s) as set by State: | |
| | | | | | | | pH 7.2 | |
| | | | | | | | | |
| | | | | | |] | | |
| | | | | | |] | | |
| | | | | | |] | | |
| | | | | | |] | | |
| | | | | | | Print | Name: Loni Weinnan | |
| | | | | | | 1 | ature: for M Win | |
| | | _ | | | | Data | 4/6/2022 | |
| <u> </u> | <u></u> | | <u> </u> | <u> </u> | | - | , | |
| 10 = | N = Ex | cursio | n) Tot a | li N'S | | | to DWP within 10 days after end of line period | |