Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1/6	7.2				
1/7	7.6				
1/8	7.8				
1/9	7.7				
1/10	7.5				
1/13	7.5				
1/14	7.6				
1/15	7.5				
1/16	7.6				
1/17	7.6				
1/21	7.4				
1/22	7.3				
1/23	7.3				
1/24	7.4				
1/27	7.6				
1/28	7.5				
1/29	7.6				
1/31	7.7				

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Linn Agency: Linn

ENTRY POINT

EP-A

PWS ID 4191707

PLEASANT VALLEY ELEM SD #55

Sample period: January 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference emailed 2-4-2025

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Loni Weinman

Signature: Loni M Wein

Date: 2-4-2025

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: wwww.ohd.hr.state.or.us/dwp