



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
2/3	7.7				
2/4	7.7				
2/5	7.5				
2/6	7.5				
2/7	7.6				
2/10	7.5				
2/11	7.4				
2/12	7.7				
2/13	closed due to weather				
2/14	7.8				
2/18	7.8				
2/19	7.7				
2/20	7.6				
2/21	7.3				
2/24	7.2				
2/25	7.6				
2/26	7.5				
2/27	7.4				
2/28	7.3				

<<Have minimums been met for this day?

County: Linn Agency: Linn
ENTRY POINT
EP-A
PWS ID 4191707
PLEASANT VALLEY ELEM SD #55
 Sample period: February 2025
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference emailed 3-11-25
Minimum Water Quality Parameter(s) as set by State:
 pH 7.2

Print Name: Loni Weinman
 Signature: [Signature]
 Date: 3-11-25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0