Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DHS oregon department of human services

Day	pH	Alk	Phos	Sili	Y/N
2/2	7.6				
2/3	7.6				
2/4	7.6				
2/5	7.5				
2/6	7.5				
2/9	7.5				
2/10	7.5				
2/11	7.5				
2/12	7.5				
2/13	7.5				
2/17	7.5				
2/18	7.5				
2/19	7.5				
2/20	7.5				
2/23	7.5				
2/24	7.5				
2/25	7.5				
2/26	7.5				
2/27	7.5				

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Linn Agency: Linn

ENTRY POINT

EP-A

PWS ID 4191707

PLEASANT VALLEY ELEM SD #55

Sample period: February 2026
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference emailed 3-10-2026

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Loni Weinman

Signature: Loni M Weinman

Date: 3-10-2026

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: wwww.ohd.hr.state.or.us/dwp