Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DHS oregon department of human services

Day	pH	Alk	Phos	Sili	Y/N
3/2	7.5				
3/3	7.5				
3/4	7.5				
3/5	7.5				
3/6	7.5				
3/9	7.6				
3/10	7.6				
3/11	7.5				
3/12	7.5				
3/13	7.5				
3/16	7.5				
3/17	7.5				
3/18	7.5				
3/19	7.5				
3/20	7.6				
3/23	7.6				
3/24	7.6				
3/25	7.6				
3/26	7.6				
3/27	7.6				
3/30	7.6				
3/31	7.6				

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Linn Agency: Linn

ENTRY POINT

EP-A

PWS ID 4191707

PLEASANT VALLEY ELEM SD #55

Sample period: March 2026
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference emailed 4-7-26

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Lori Weinman

Signature: Lori M Weinman

Date: 4-7-26

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: wwww.ohd.hr.state.or.us/dwp