Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DHS oregon department of human services

Day	pH	Alk	Phos	Sili	Y/N
2/1	7.3				
2/2	7.5				
2/3	–				
2/4	7.4				
2/5	7.5				
2/8	7.4				
2/9	7.5				
2/10	7.6				
2/11	7.5				
2/12	7.7				
2/16	7.4				
2/17	7.6				
2/18	7.6				
2/19	7.5				
2/22	7.3				
2/23	7.6				
2/24	7.6				
2/25	7.6				
2/26	7.5				

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

County: Linn Agency: Linn

ENTRY POINT

EP-A

PWS ID 4191707

PLEASANT VALLEY ELEM SD #55

Sample period: February 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Lori Weinman

Signature: Lori M Weinman

Date: 3-4-2021

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: wwww.ohd.hr.state.or.us/dwp