

Pleasant Valley School
 28028 Pleasant Valley Rd
 Sweet Home, Or 97386

March

Pleasant Valley Daily Water Tests

Free Chlorine Readings
 Target Range: 0.2 - 1.4 mg/l

PH Readings
 Target Range: 7.2 - 8.1

Name	Date	Boiler Rm. (daily)	Rm. 5 (2x per wk)	Source (well head)	Boiler Rm (tank)	Rm. 5
Josh	3/1	.6	.5	7.6	7.4	7.4
Josh	3/2	.8	.7	7.8	7.6	7.6
Josh	3/3	.7	.6	7.9	7.5	7.5
Josh	3/4	.4	.6	7.9	7.6	7.5
Josh	3/5	.7	.6	7.8	7.5	7.5
Josh	3/8	.6	.6	7.8	7.3	7.3
Josh	3/9	.6	.55	7.7	7.5	7.4
Josh	3/10	.6	.5	7.8	7.6	7.4
Josh	3/11	.6	.6	7.8	7.5	7.5
Josh	3/12	.7	.5	7.7	7.4	7.4
Josh	3/15	.6	.3	7.7	7.4	7.6
NH	3/16	.6	.2	7.6	7.6	7.5
NH	3/17	1.2	1	7.8	7.6	7.6
NH	3/18	1.1	1.0	7.6	7.9	7.6
Josh	3/19	.9	.9	7.3	7.2	7.4
Josh	3/22	.4	.5	7.3	7.2	7.2
Josh	3/23	.8	.6	7.6	7.3	7.3
Josh	3/26	.7	.6	7.6	7.3	7.3
Josh	3/29	1.0	.6	7.6	7.3	7.4
Josh	3/30	1.3	1.4	7.6	7.2	7.3
Josh	3/31	.7	.9	7.7	7.4	7.3