

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have< th=""></have<>			
1						minimums ENTRY POINT been met for			
2	7.10		1		V				
3						this day? PWS ID: 41 9 1 7 1 7			
4						System Name: Diamond Hill RV			
5	7.23	0000000	1		V	Entry Point: EP - A			
6					_	Sample Period: February			
7						Month/Year/			
8						Number of excursions* during this month:			
9	7.20		1		Y	(Count the number of days when any WQP was less than the minimum required) Total excursions during the previous 5 months: (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative) —For OHA use only			
10									
11									
12	7.17		1		V				
13									
14									
15									
	7.20		1		Y				
17						Minimum Water Quality			
18						Parameters as set by pH 7.0 Alk (Alkalinity) PO4 1.0 (Orthophosphate) Other ()			
19	7.25			\	$\sqrt{}$				
20									
21									
22									
-	7.24		1	\	1				
	7.22		1	1	4				
25									
	7.31			1	1				
27						Print Name: Socret Scencer			
-	7-28		1)		Print Name: Secret Spencer Signature:			
29						Date: 3/5/2/			
30									
31						Send to DWP within 10 days after end of sampling period			

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/