

Day	pH	Alk	Phos	Other	Y/N
1	7.23		1		Y
2					
3					
4	7.31		1		Y
5					
6					
7					
8	7.30		1		Y
9					
10					
11	7.35		1		Y
12					
13					
14					
15	7.40		1		Y
16					
17					
18	7.42		1		Y
19					
20					
21					
22	7.35		1		Y
23					
24					
25	7.45		1		Y
26					
27					
28					
29	7.42		1		Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Diamond Hill RV

Entry Point: EP - A

Sample Period: September 2021
Month/Year

Number of excursions* during this month:
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1.0"/>	(Orthophosphate)
Other	<input type="text"/>	()

Print Name: Secret Spencer

Signature:

Date: 10/1/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's