

## Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1						minimums
2						been met for this day? PWS ID: 41 9 1 7 1 7
3						System Name: Diamond Hill RV
4	7.50		1		Y	
5					,	Entry Point: EP - A
6						Sample Period: January 2027
7	7.50				Y	Month/Year
8						Number of excursions* during this month:
9						(Count the number of days when any WQP was
10						less than the minimum required)
11	7.40		1		٧	
12						Total excursions during the previous 5 months:
13						(Over 9 excursions in 6 months is a violation. Entry
14	7-38		1		Y	Point and Distribution excursions are cumulative)
15						For OHA use only
16						
17						Minimum Water Quality
18	7.33		1		Y	Parameters as set by
19						pH 7.0
20						Alk (Alkalinity)
21	7.35				Y	PO4 1.0 (Orthophosphate)
22						Other (Charlespriate)
23						Other
24						
25	7.30		lì		Y	
26						
27						Print Name: <u>Secret Spencer</u>
28	7.31				y	Signature:
29						Date: 2110 22
30						Send to DWP within 10 days after end of
31						sampling period
No = N = Excursion) Total N's						
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/