

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>	
1	7.31		1		4	minimums	
2				Ì		been met for this day? PWS ID: 41 9 17	
3						System Name: Deamon & Hell RV	
4							
5	1.33	,	1		1	Entry Point: EP-A	
6					,	Sample Period: April 2027 Month/Year	
7						~	
8	7-39		1		7	Number of excursions* during this month:	
9	,					(Count the number of days when any WQP was	
10						less than the minimum required)	
11						₽	
12	7-32	-	1		\/	Total excursions during the previous 5 months:	
13						(Over 9 excursions in 6 months is a violation. Entry	
14						Point and Distribution excursions are cumulative)	
15	7.27				7	For OHA use only	
16		1					
17						Minimum Water Quality	
18						Parameters as set by	
19	7.33		1		Y	pH 7.0	
20						Alk (Alkalinity)	
21						(Outle and a sub a to)	
22	7.3)		1		V	7.0	
23						Other	
24							
25							
26	7.29				Y		
27						Print Name:	
28						Signature:	
29	7.23				Y	Date: 5522	
30						Send to DWP within 10 days after end of	
31						sampling period	
No =	No = N = Excursion) Total N's						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/