

## Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other Y/I	
1	7.23			γ	minimums been met for
2					this day? PWS ID: 41 9 1 7 1 7
3					System Name: Diamond Hill RV
4	7.25			Y	
5					Entry Point: EP - A
6					Sample Period:
7					
8	7.27			7	Number of excursions* during this month:
9					(Count the number of days when any WQP was
10					less than the minimum required)
11	7.26		1		
12				,	Total excursions during the previous 5 months:
13					(Over 9 excursions in 6 months is a violation. Entry
14					Point and Distribution excursions are cumulative )
15	7-27		l	۸	For OHA use only
16					
17					Minimum Water Quality
18	7.27			~	Parameters as set by
19					pH 7.0
20					Alk (Alkalinity)
21					PO4 1.0 (Orthophosphate)
22	7-25		1		Other (
23					Other
24					
25	7.21		1		
26			,		
27					Print Name: Secret Spencer
28					Signature:
29	7.20		1		Date: 81127
30				/	Send to DWP within 10 days after end of
31					sampling period
(No = N = Excursion) Total N's					
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350					

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/