



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.23		1		Y
4					
5					
6					
7	7.20		1		Y
8					
9					
10	7.21		1		Y
11					
12					
13					
14	7.22		1		Y
15					
16					
17	7.35		1		Y
18					
19					
20					
21	7.39		1		Y
22					
23					
24	7.38		1		Y
25					
26					
27					
28	7.39		1		Y
29					
30					
31					

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 9 1 7 1 7

System Name: Diamond Hill RV

Entry Point: EP - A

Sample Period: February 2023  
Month/year

Number of excursions\* during this month: \_\_\_\_\_  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

#### Minimum Water Quality Parameters as set by

pH	7.0	
Alk		<i>(Alkalinity)</i>
PO4	1.0	<i>(Orthophosphate)</i>
Other		<i>(_____)</i>

Print Name: Secret Spencer

Signature:

Date: 3/1/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 9