



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DAY	PH	ALK	Phos	Other	Y/N
1					
2					
3	7.41		1		Y
4					
5					
6					
7	7.42		1		Y
8					
9					
10	7.48		1		Y
11					
12					
13					
14	7.42		1		Y
15					
16					
17	7.4		1		Y
18					
19					
20					
21	7.39		1		Y
22					
23					
24	7.44		1		Y
25					
26					
27					
28	7.41		1		Y
29					
30					
31	7.51		1		Y

<<Have Minimums been met for this day?

ENTRY POINT

PWS: 41

9	1	7	1	7
---	---	---	---	---

Item Name: Diamond Hill RV

Entry Point EP-A

Sample Period Mar-23

Number of excursions* during this month _____

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	7	
Alk		Alkalinity
PO4	1	Orthophosphate
Other		

Print Name: Secret Spencer

Signature:

Date: 4/8/2023

Send to DWP within 10 days after end of sampling period