

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

DAY	PH	ALK	Phos	Other	Y/N	
1						< <have entry="" minimums<="" point="" td=""></have>
2						been met for PWS: 41 9 1 7 1 7
						this day?
3			_			
4	7.34		1		Υ	Entry Point EP-A
5						Sample Period
6						
7	7.39		1		Υ	Number of excusions*during this month 0
8						(Count the numbe rof days whenany WQP was less than the minimum required)
9						<u></u>
10						Total excusions during the preious 5 months 0
11	7.32		1		Υ	
12						(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative
13						
14	7.37		1		Υ	For OHA Use Only
15						
16						Minimum Wate rQuality
17						Paramaters as set by
18	7.41		1		Υ	ph 7
19						Alk Alkalinity
20						PO4 1 Orthophospate
	7.20		1		Υ	
21	7.39		1		Y	Other
22						
23						-
24						
25	7.37		1		Υ	Print Name: Secret Spencer
26						Signature:
27						Date: 5/10/2023
28	7.35		1		Υ	Send to DWP within 10 days after end of
29						sampling period
30						
31						