



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DAY	PH	ALK	Phos	Other	Y/N
1					
2	7.34		1		Y
3					
4					
5	7.39		1		Y
6					
7					
8					
9	7.32		1		Y
10					
11					
12	7.37		1		Y
13					
14					
15					
16	7.41		1		Y
17					
18					
19	7.39		1		Y
20					
21					
22					
23	7.37		1		Y
24					
25					
26	7.35		1		Y
27					
28					
29					
30	7.39		1		Y
31					

<<Have Minimums been met for this day?

ENTRY POINT

PWS: 41

9	1	7	1	7
---	---	---	---	---

Item Name: Diamond Hill RV

Entry Point EP-A

Sample Period May

Number of excursions* during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality

Parameters as set by

ph	<u>7</u>	
Alk		Alkalinity
PO4	<u>1</u>	Orthophosphate
Other		

Print Name: Secret Spencer

Signature:

Date: 6/6/2023

Send to DWP within 10 days after end of sampling period