

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DAY	PH	ALK	Phos	Other	Y/N	oper Rule Corresion Control
1						< <have entry="" minimums<="" point="" td=""></have>
2	7.34		1		Υ	been met for PWS: 41 9 1 7 1 7
3						this day? tem Name: Diamond Hill RV
4						Entry Point EP-A
5						Sample Period June
6	7.39		1.00		Y/N	
7						Number of excusions*during this month 0
8						(Count the numbe rof days whenany WQP was less than the minimum required)
9	7.37		1		Υ	
10						Total excusions during the preious 5 months 0
11						
12						(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative
13	7.36		1		Υ	
14						For OHA Use Only
15						
16	7.38		1		Υ	Minimum Wate rQuality
17						Paramaters as set by
18						ph 7
19	7.37		1		Υ	Alk Alkalinity
20						PO4 1 Orthophospate
21						Other
22						
23	7.36		1		Υ	
24						
25						Print Name: Secret Spencer
26	7.39		1		Υ	Signature:
27						Date: 7/7/2023
28						Send to DWP within 10 days after end of
29						sampling period
30	7.39		1		Υ	
31						