



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DAY	PH	ALK	Phos	Other	Y/N
1	7.38		1		Y
2					
3					
4	7.37		1		Y
5					
6					
7					
8	7.39		1		Y
9					
10					
11	7.39		1		Y
12					
13					
14					
15	7.35		1		Y
16					
17					
18	7.35		1		Y
19					
20					
21					
22	7.37		1		Y
23					
24					
25	7.38		1		Y
26					
27					
28					
29	7.39		1		Y
30					
31					

<<Have Minimums been met for this day?

ENTRY POINT

PWS: 41

9	1	7	1	7
---	---	---	---	---

tem Name: Diamond Hill RV

Entry Point EP-A

Sample Period August

Number of excursions* during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality

Parameters as set by

ph	<u>7</u>	
Alk		Alkalinity
PO4	<u>1</u>	Orthophosphate
Other		

Print Name: Secret Spencer

Signature:

Date: 9/3/2023

Send to DWP within 10 days after end of sampling period