



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

DAY	PH	ALK	Phos	Other	Y/N
1					
2					
3	7.3		1		Y
4					
5					
6	7.28		1		Y
7					
8					
9					
10	7.33		1		Y
11					
12					
13	7.35		1		Y
14					
15					
16					
17	7.35		1		Y
18					
19					
20	7.38		1		Y
21					
22					
23					
24	7.37		1		Y
25					
26					
27	7.37		1		Y
28					
29					
30					
31	7.39		1		Y

<<Have Minimums been met for this day?

**ENTRY POINT**

**PWS: 41**

9	1	7	1	7
---	---	---	---	---

**Item Name:** Diamond Hill RV

**Entry Point** EP-A

**Sample Period** Oct-23

**Number of excursions\* during this month** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	<u>7</u>	
Alk		Alkalinity
PO4	<u>1</u>	Orthophosphate
Other		

**Print Name:** Secret Spencer

**Signature:** 

**Date:** 11/2/2023

Send to DWP within 10 days after end of sampling period