	Orogon	
	Olegon	Hh
	Ca	ш
2.2	000	Authority

## Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

DAY	PH	ALK	Phos	Other	Y/N		
1						< <have entry="" point<="" th=""></have>	
2	7.47		1		Y/N	been met for PWS: 41 9 1 7 1 7	
3						this day?	
4						Entry Point EP-A	
5						Sample Period Feb-24	
6	7.44		1		Y/N		
7						Number of excusions*during this month 0	
8						(Count the numbe rof days whenany WQP was less than the minimum required)	
9	7.44		1		Y/N		
10						Total excusions during the preious 5 months 0	
11							
12						(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative	
13	7.37		1		Y/N		
14						For OHA Use Only	
15						_	
16	7.38		1		Y/N	Minimum Wate rQuality	
17						Paramaters as set by	
18						ph 7	
19						Alk Alkalinity	
20	7.37		1		Y/N	PO4 1 Orthophospate	
21						Other	
22							
23	7.37		1		Y/N	_	
24						_	
25						Print Name: Secret Spencer	
26						Signature:	
27	7.36		1		Y/N	Date: 3/1/2024	
28						Send to DWP within 10 days after end of	
29						sampling period	
						_	