



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

DAY	PH	ALK	Phos	Other	Y/N
1	7.37		1		Y/N
2					
3					
4					
5	7.38		1		Y/N
6					
7					
8	7.36		1		Y/N
9					
10					
11					
12	7.41		1		Y/N
13					
14					
15	7.40		1		Y/N
16					
17					
18					
19	7.42		1		Y/N
20					
21					
22	7.43		1		Y/N
23					
24					
25					
26	7.43		1		Y/N
27					
28					
29	7.42		1		Y/N
30					
31					

<<Have Minimums been met for this day?

**ENTRY POINT**

**PWS: 41**

9	1	7	1	7
---	---	---	---	---

**Item Name:** Diamond Hill RV

**Entry Point** EP-A

**Sample Period** Mar-24

**Number of excursions\* during this month** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality

Parameters as set by

ph	<u>7</u>	
Alk		Alkalinity
PO4	<u>1</u>	Orthophosphate
Other		

**Print Name:** Secret Spencer

**Signature:**

**Date:** 4/3/2024

Send to DWP within 10 days after end of sampling period