

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DAY	PH	ALK	Phos	Other	Y/N	, por real of real or control
1						< <have entry="" minimums<="" point="" td=""></have>
2	7.42		1.00		Υ	been met for PWS: 41 9 1 7 1 7
3						this day? tem Name: Diamond Hill RV
4						Entry Point EP-A
5	7.44		1.00		Υ	Sample Period Mar-24
6						7
7						0 Number of excusions*during this month
8						(Count the numbe rof days whenany WQP was less than the minimum required)
9	7.43		1.00		Υ	
10						Total excusions during the preious 5 months 0
11						<u> </u>
12	7.44		1.00		Υ	(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative
13						
14						For OHA Use Only
15						
16	7.47		1.00		Υ	Minimum Wate rQuality
17						Paramaters as set by
18						ph 7
19	7.51		1.00		Υ	Alk Alkalinity
20						PO4 1 Orthophospate
21						Other
22]
23	7.49		1.00		Υ	
24						
25						Print Name: Secret Spencer
26	7.47		1.00		Υ	Signature: 55pm
27						Date: 4/30/2024
28						Send to DWP within 10 days after end of
29						sampling period
30	7.46		1.00		Υ]
	3		2.00			1