



# Water Quality Parameter Monitoring Form & Copper Rule Corrosion Control

DAY	PH	ALK	Phos	Other	Y/N
1					
2					
3	7.41		1.00		Y
4					
5					
6			1.00		Y
7	7.45				
8					
9					
10	7.49		1.00		Y
11					
12					
13			1.00		Y
14	7.47				
15					
16					
17	7.47		1.00		Y
18					
19					
20			1.00		Y
21	7.46				
22					
23					
24	7.45		1.00		Y
25					
26					
27	7.44		1.00		Y
28					
29					
30					
31	7.45		1.00		Y

<<Have Minimum s been met for

**ENTRY POINT**

PWS: 4: 

9	1	7	1	7
---	---	---	---	---

Name: Diamond Hill RV

Entry Point EP-A

Sample Period May-24

Number of excursions\* during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	<u>7</u>	
Alk		Alkalinity
PO4	<u>1</u>	Orthophosphate
Other		

Print Name: Secret Spencer

Signature: 

Date: 6/4/2024

Send to DWP within 10 days after end of sampling period