



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| DAY | Phos | Other | Y/N |
|-----|------|-------|-----|
| 1 | | | |
| 2 | 7.44 | 1.00 | Y |
| 3 | | | |
| 4 | | | |
| 5 | 7.45 | 1.00 | Y |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | 7.43 | 1.00 | Y |
| 10 | | | |
| 11 | | | |
| 12 | 7.44 | 1.00 | Y |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | 7.45 | 1.00 | Y |
| 17 | | | |
| 18 | | | |
| 19 | 7.43 | 1.00 | Y |
| 20 | | | |
| 21 | | | |
| 22 | | | |
| 23 | 7.44 | 1.00 | Y |
| 24 | | | |
| 25 | | | |
| 26 | 7.41 | 1.00 | Y |
| 27 | | | |
| 28 | | | |
| 29 | | | |
| 30 | 7.43 | | Y |
| 31 | | | |

<<Have Minimums been met for this day? **PWS** 9 1 7 1 7

name: Diamond Hill RV

Entry Point EP-A

Sample Period Jul-24

Number of excursions during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 6 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

| | | |
|-------|---|----------------|
| pH | 7 | |
| Alk | | Alkalinity |
| PO4 | 1 | Orthophosphate |
| Other | | |

Print Name Secret Spencer

Signature: _____

Date: 8/1/2024

Send to DWP within 10 days after end of sampling period