



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

DAY	Phos	Other	Y/N
1			
2	7.38	1.00	Y
3			
4			
5			
6	7.38	1.00	Y
7			
8			
9	7.39	1.00	Y
10			
11			
12			
13	7.37	1.00	Y
14			
15			
16	7.38	1.00	Y
17			
18			
19			
20	7.38	1.00	Y
21			
22			
23	7.40	1.00	Y
24			
25			
26			
27	7.41	1.00	Y
28			
29			
30	7.44	1.00	Y
31			

<<Have Minimums been met for this day? **PWS** 9 1 7 1 7

name: Diamond Hill RV

Entry Point EP-A

Sample Period Aug-24

Number of excursions during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 6 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	7	
Alk		Alkalinity
PO4	1	Orthophosphate
Other		

Print Name Secret Spencer

Signature: _____

Date: 9/4/2024

Send to DWP within 10 days after end of sampling period