

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DAY	PH	ALK	Phos	Other	Y/N	
1	7.49		1.00		Υ	< <have entry="" minimums<="" point="" td=""></have>
2						been met for hthis day?
3						tem Name: Diamond Hill RV
4						Entry Point EP-A
5	7.48		1.00		Υ	Sample Period Dec-23
5						
7						Number of excusions*during this month
3	7.38		1.00		Υ	(Count the numbe rof days whenany WQP was less than the minimum required)
9						<u></u>
10						Total excusions during the preious 5 months
11						
12	7.38		1.00		Υ	(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative
13						
14						For OHA Use Only
15	7.39		1.00		Υ	
16						Minimum Wate rQuality
17						Paramaters as set by
18						ph 7
19	7.37		1.00		Υ	Alk Alkalinity
20						PO4 1 Orthophospate
21						Other
22	7.38		1.00		Υ	
23						
24						
25						Print Name: Secret Spencer
26	7.38		1.00		Υ	Signature: Sspencer
27						Date: 11/5/2024
28						Send to DWP within 10 days after end of
29	7.37		1.00		Υ	sampling period
30						
31						