



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

DAY	Authority	Phos	Other	Y/N
1				
2				
3	7.48	1.00		Y
4				
5				
6	7.48	1		Y
7				
8	7.47	1.00		Y
9				
10	7.48	1		Y
11				
12				
13	7.47	1.00		Y
14				
15				
16				
17	7.47	1		Y
18				
19				
20	7.48	1.00		Y
21				
22				
23				
24	7.48	1		Y
25				
26				
27	7.46	1.00		Y
28				
29				
30				
31	7.46	1		Y

<<Have Minimums been met for this day?

PWS: 41

System Name: Diamond Hill RV

Entry Point: EP-A

Sample Period: Dec-25

ENTRY POINT

9	1	7	1	7
---	---	---	---	---

Number of excursions* during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	7	
Alk		Alkalinity
PO4	1	Orthophosphate
Other		

Print Name: Secret Spencer

Signature: _____

Date: 1/2/2025

Send to DWP within 10 days after end of sampling period