



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

DAY	Phos	Other	Y/N
1			
2			
3	7.48	1.00	Y
4			
5			
6			
7	7.47	1.00	Y
8			
9			
10	7.47	1.00	Y
11			
12			
13			
14	7.46	1.00	Y
15			
16			
17	7.46	1.00	Y
18			
19			
20			
21	7.47	1.00	Y
22			
23			
24	7.47	1.00	Y
25			
26			
27			
28	7.46	1.00	Y
29			
30			
31	7.48	1	Y

<<Have Minimums been met for this day?

PWS: 41

System Name: Diamond Hill RV

Entry Point: EP-A

Sample Period: Jan-25

ENTRY POINT				
9	1	7	1	7

Number of excursions* during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality

Parameters as set by

ph	7	
Alk		Alkalinity
PO4	1	Orthophosphate
Other		

Print Name: Secret Spencer

Signature:

Date: 1/31/2025

Send to DWP within 10 days after end of sampling period