



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

DAY	Phos	Other	Y/N
1	7.50	1.00	Y
2			
3			
4	7.51	1	Y
5			
6			
7	7.52	1.00	Y
8			
9			
10			
11	7.55	1	Y
12			
13			
14	7.53	1	Y
15			
16			
17			
18	7.52	1.00	Y
19			
20			
21	7.50	1	Y
22			
23			
24			
25	7.45	1	Y
26			
27			
28	7.43	1	Y

<<Have Minimums been met for this day?

**PWS: 41**

**System Name:** Diamond Hill RV

**Entry Point:** EP-A

**Sample Period:** Feb-25

**ENTRY POINT**

9	1	7	1	7
---	---	---	---	---

**Number of excursions\* during this month** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	7	
Alk		Alkalinity
PO4	1	Orthophosphate
Other		

**Print Name:** Secret Spencer

**Signature:**

**Date:** 3/3/2025

Send to DWP within 10 days after end of sampling period