


Oregon Health Authority		Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control								
DAY		Phos	Other	Y/N						
1					<div><<Have Minimums been met for this day?</div> <div>PWS: 41</div> <div>ENTRY POINT</div> <table border="1"><tr><td>9</td><td>1</td><td>7</td><td>1</td><td>7</td></tr></table> <div>System Name: Diamond Hill RV</div> <div>Entry Point EP-A</div> <div>Sample Period Jun-25</div>	9	1	7	1	7
9	1	7	1	7						
2										
3	7.45	1		Y						
4										
5										
6	7.44	1		Y						
7					Number of excursions* during this month 0					
8					(Count the number of days when any WQP was less than the minimum required)					
9										
10	7.45	1		Y	Total excursions during the previous 5 months 0					
11										
12					(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)					
13	7.44	1		Y						
14										
15										
16										
17	7.44	1		Y						
18										
19										
20	7.51	1		Y						
21										
22										
23										
24	7.55	1		Y						
25										
26										
27	7.56	1		Y						
28										
29										
30										

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	7	
Alk		Alkalinity
PO4	1	Orthophosphate
Other		

Print Name: Secret Spencer

Signature: 

Date: 7/1/2025

Send to DWP within 10 days after end of sampling period