

 Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control					
DAY	PH	ALK	Phos	Other	Y/N
1	7.47		1.00		Y
2					
3					
4					
5	7.44		1		Y
6					
7					
8	7.40		1.00		Y
9					
10					
11					
12	7.44		1		Y
13					
14					
15	7.43		1		Y
16					
17					
18					
19	7.42		1		Y/N
20					
21					
22	7.42		1		Y
23					
24					
25					
26	7.43		1		Y
27					
28					
29	7.44		1		Y
30					
31					

<<Have Minimums been met for this day?

ENTRY POINT

PWS: 41

9	1	7	1	7
---	---	---	---	---

n Name: Diamond Hill RV

Entry Point EP-A

e Period Jul-25 

Number of excursions* during this month 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	<u>7</u>	
Alk		Alkalinity
PO4	<u>1</u>	Orthophosphate
Other		

Print Name: Secret Spencer

Signature: 

Date: 9/4/2025

Send to DWP within 10 days after end of sampling period