

 Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control					
DAY	PH	ALK	Phos	Other	Y/N
1					
2	7.44		1.00		Y
3					
4					
5	7.43		1.00		Y
6					
7					
8					
9	7.41		1.00		Y
10					
11					
12	7.41		1.00		Y
13					
14					
15					
16	7.40		1.00		Y
17					
18					
19	7.40		1.00		Y
20					
21					
22					
23	7.40		1.00		Y
24					
25					
26	7.41		1.00		Y
27					
28					
29					
30	7.40		1.00		Y
31					

<<Have Minimums been met for this day?

ENTRY POINT

PWS: 41

9	1	7	1	7
---	---	---	---	---

n Name: Diamond Hill RV

ry Point EP-A

e Period Sep-25

Number of excursions* during this month 0
(Count the number of days when any WQR was less than the minimum required)

Total excursions during the previous 5 months 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	<u>7</u>	
Alk		Alkalinity
PO4	<u>1</u>	Orthophosphate
Other		

Print Name: Secret Spencer

Signature: 

Date: 10/3/2025

Send to DWP within 10 days after end of sampling period